

HEATIZON

This authorizes the application of the Certification Marks shown below to the models described in the Products(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to the multiple listee model(s) identified on the correlation page of the Listing Report.

Applicant:

Heatwave LLC dba Heatizon

4137 South 500 West Murray, UT 84132

Contact:

Name: Mr. Russell Childs

Phone: 801.293.1232

Manufacturer:

Same as Applicant

Party Authorized To Apply Mark:

Same as Manufacturer

Report Issuing Office: Beaverton, OR

Report No.:

3013496-5

Product Covered:

In-floor radiant heating systems, Floorizwarm AC and Floorizwarm DC systems,

models FLZ1520AC, FLZ2030AC, FLZ2536AC, FLZ3650AC, FLZ5064AC,

FLZ6475AC, FLZ75110AC, FLZ1622DC, FLZ2228DC, FLZ2840DC, FLZ4054DC,

FLZ5475DC, and FLZ75110DC.

Description:

The products covered by this Report are in-floor electric radiant heating systems. Each system consists of a permanently-connected power supply and heating conductors poured in concrete which have integral cold leads which are connected to the output of the power supply. The heating cables are intended to

be installed in poured concrete or tile grout.

Standard(s):

Power Units Other Than Class 2 (UL 1012, Seventh Edition, Revisions through and lincluding February 23, 2006) and Electric Space Heating Cables (UL 1673,

Second Ed., 05/30/1996)

This document is the property of Intertek Testing Services and is not transferable. Only the Applicant may reproduce this document. The certification mark(s) may be applied only at the above noted location of the Party Authorized To Apply Mark.



Authorized by

Control Number:

This document supersedes all previous Authorizations to Mark for the noted Report number.

Intertek Testing Services NA Inc. 165 Main Street, Cortland, NY 13045 Telephone 800-345-3851 or 607-753-6711 Fax 607-756-6699