



NOTE: FOR CBX6T OR CBX23T THE BLACK AND WHITE LEADS ON THE M326 CONNECT INTO THE CONTROL UNIT IN THE BLACK AND YELLOW TERMINALS. IF THE SYSTEM IS NOT USING A CBX6T OR CBX23T, A HEATIZON SYSTEMS 24V TRANSFORMER (PART #M360) IS REQUIRED TO POWER THE ACTIVATION DEVICE.

REV:	DATE:	DESCRIPTION
C	05/17/10	M326 AERIAL SNOW SWITCH W/M325D
M326 AERIAL MOUNTED SNOW SWITCH W/M325D		
DATE: May 17, 2010		DRAWN BY: ACI

HEATIZON SYSTEMS
advanced floor heating/snow and ice removal systems
 4137 SOUTH 500 WEST, MURRAY, UTAH 84123 (801) 293-1232 FAX (801) 293-3077